

NC802DEWM

Water Resistant Alert Point IP65 Magnetic Reset



Overview

A surface-mounting IP65 rated water-resistant alert point capable of generating Standard or Emergency calls on an 800 Series Call System.

Comprises a light grey back box, yellow lid and bright red push button.

Ideal for use alongside swimming pools and other 'wet' areas.

Red reassurance LED confirms a call has been made.

Includes an onboard magnetic reset facility (requires an NC803M magnetic reset key, not supplied). Alternatively wire to a separate 800 Series reset point.

Supplied with two stickers, one reading 'Call for Assistance' and one reading 'Push for EMERGENCY'.

Slave IP65 water-resistant alert points (NC802DEWS) and IP69K sauna alert points (NC802DESS) also available.

Technical Specifications

Quiescent current	0mA (none).
Alarm current	Determined by the type of control equipment and number / type of field devices connected to the system.



Indicators	Red Reassurance LED (lit constant for Standard calls, intermittently for Emergency calls).
Controls	Red Alert button (generates Standard or Emergency calls depending on the wiring configuration used); Magnetic reset 'target' (cancels Standard or Emergency calls from the NC802DEWM and Standard calls from devices wired on the same Zone).
Connections	Yellow (Signal); Black (Negative); Red (Positive); White (Common Switch); Brown (Emergency Call trigger); Orange (Standard Call trigger); Green (Manual Reset). See instructions for details.
Expansion connections	Yes, for optional NC802DEWS slave water resistant alert points and remote reset points.
Onboard 6.35mm Remote Jack Socket	No.
Onboard Infrared Receiver	No.
Product dimensions (mm)	65 W x 65 H x 75 D. Surface mounting.
Construction & finish	Polycarbonate. Red push button, yellow fascia, grey back box.
IP Rating	IP65.
Weight	136g.
Operating conditions/temperature	-0°C to +40°C. Max. relative humidity 95% non-condensing.





CIE-Group Ltd
3 Widdowson Close
Blenheim Ind Est
Bulwell
Nottingham
NG6 8WB

Email: info@cie-group.com
Telephone: 0115 9770075

